


SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by **Er. Ayush Gwal (Assistant Engineer)** from **Uttarakhand Jal Sansthan, Khatima** inspected the **SINGH INTERNATIONAL SCHOOL, Vill- Majhola, Tehsil- Khatima, Udham Singh Nagar, Uttarakhand** on **21-07-2025** and on the basis of Water Test Report (Attached) bearing no **74/UJS/DLWQTML/2025-26** dated **29-07-2025** of **District Level Water Quality Testing and Monitoring Laboratory, Uttarakhand Jal Sansthan, Rudrapur, Udham Singh Nagar** certified that **SINGH INTERNATIONAL SCHOOL** has safe drinking water facilities for the students and staff members of the institution. School also maintains hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State U.T. Govt.

This certificate is valid till 28 07 2028


Er. Ajay Kumar
Executive Engineer
Uttarakhand Jal Sansthan, Khatima
Udham Singh Nagar (Uttarakhand)

अधियन्ता
उत्तराखण्ड जल संस्थान
(उदधम सिंह नगर)

To,
Singh International School
Majhola, Khatima, Udham Singh Nagar
Uttarakhand



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Rudrapur U.S. Nagar
E-mail: eeudmujs@gmail.com

Test Report ID:74/UJS/DLWQTML/2025-26


WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Singh International School, vill-Majhola, The-khatima, (U.S. Nagar)		
Type of Source (Drinking Water/ Ground Water/ Sub-Surface Water)	Sample Description: Drinking Water	One water Sample Collect from School campus RO	
Reference Sample Identification:	DLWQTML/UJS/SIS-01	Date of Start of Analysis: 21.07.2025	
Date of Sample Received: 21.07.2025, 11:55AM	Sample Collected by:	Date of End of Analysis : 29.07.2025 Customer	

S.No.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)
1	Colour	Less than 1	5	15
2	Odour	Unobjectionable	Unobjectionable	Unobjectionable
3	Taste	Agreeable	Agreeable	Agreeable
4	Total Dissolved Solids (TDS), mg/l max	95	500	2000
5	pH at 25°C	7.18	6.5 to 8.5	No Relaxation
6	Turbidity, NTU max	0.41	1	5
7	Chloride, Mg/l max	7.99	250	1000
8	Total Alkalinity as CaCO ₃ mg/l max	41	200	600
9	Total Hardness as CaCO ₃ mg/l max	68	200	600
10	Calcium as Ca mg/l max	14.4	75	200
11	Magnesium as Mg mg/l max	7.77	30	100
Microbiological Test Parameters				
12	E.Coli MPN /100ml	Absent	Absent	Absent
13	Total Coliform/100ml	Absent	Absent	Absent


Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


Chemist


Technical Manager
Lab Incharge/Quality Manager
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S. Nagar

-End of Report-

Scm


अधिसासी अभियन्ता
उत्तराखण्ड जल संस्थान
खटीमा (ऊधम सिंह नगर)